Hi-Tech Fire Alarm Systems

DECLARATION OF CONFORMITY

Tecnoalarm srl declare under their sole responsibility that the product which this declaration relates to:

Name:	**TFES01**
Description:	Outdoor siren

is in compliance with all relevant essential requirements and other relevant provisions of the directives:

LVD 2006/95/EC	Low Voltage Directive
EMC 2004/108/EC	Electromagnetic Compatibility

and the regulation:

CPR 305/2011	Construction Products Regulation (CPR)

Compliance with these directives implies conformity to the following European norms:

EN 50130-4:2011	Immunity requirements for alarm systems – Intrusion and and hold-up systems – Part 4: Warning devices
EN 55022:2010	Information technology equipment - Radio disturbance characteristics - Limits and methods of measurement
EN 54-3:2001 + A2:2006	Fire detection and fire alarm systems - Part 3: Fire alarm devices and sounders

San Mauro Torinese, July 3rd, 2015

Negro Giovanni
Management

Tecnoalarm S.r.l.
Via Ciriè, 38 - 10099 San Mauro T.se - Torino (Italy) - Unità produttiva: Strada del Cascinotto, 139/54 - 10156 Torino
Tel. +39 011 22 35 410 - Fax +39 011 27 35 590 - info@tecnofiredetection.com - www.tecnofiredetection.com
R.I. e C. F./P. Iva 01792190017 - REA TO 518027 - Comm. Estero: posiz. TO 001239 - Cap. Soc. i.v.: Euro 500.000,00