Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
R 50649025 0001

Berichtsnummer *Report No.:*
CN22JTC7 006

Genehmigungsinhaber *License Holder:*
X-Sense Electronics Co., Ltd.
Room 402, Building 4, No. 9,
Jinshagang 1st Road, Shixia Village, Dalang Town,
Dongguan City,
523750 Guangdong
P.R. China

Fertigungsstätte *Manufacturing Site:*
X-Sense Electronics Co., Ltd.
Room 402, Building 4, No. 9,
Jinshagang 1st Road, Shixia Village, Dalang Town,
Dongguan City,
523750 Guangdong
P.R. China

Prüfzeichen *Test Mark:*

TÜVRheinland CERTIFIED
Type Approved
Safety
Regular Production
Surveillance
www.tuv.com
ID 1111291538

Geprüft nach *Tested according to:*
EN 50291-1:2018

Geräteidentifikation
Product Identification

Produkt: Alarm Device
Product: (Carbon Monoxide Detector)

Modell: Modelle sind auf nächste(r) Seite(n) gelistet
Type: *Type designation(s) are listed on the next page(s)*

Technische Daten: Technical data(s) are listed on the next page(s)
Technical Data: ANLAGE (Appendix): 1

Gültig ab: 2024-10-08
Valid from:

Ausstellungsdatum: 2024-10-08
Date of issue:

Zertifizierungsstelle:
Certification body:

A. Chen

TÜV Rheinland LGA Products GmbH
TÜVRheinland
Zertifizierungsstelle

® TÜV, TUEV and TUV are registered trademarks . Utilisatio n and applic ation requires prior approval.

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
R 50649025 0001

Berichtsnummer *Report No.:*
CN22JTC7 006

Produkt *Product:* Alarm Device
(Carbon Monoxide Detector)

Modell *Type:* **Bezeichnung** *Designation:*

XC01	XC01-R	XC01-WR	XC01P-WR
XC04	XC04-R	XC04-WR	XC05P-R
XC05P	XC05P-WR	XC01-M	XC04-WX
(Non-replaceable battery powered)	(Replaceable battery powered)		

Rated Voltage : DC 3.0V
Sensor Type : Electrochemical
Service Life : > 10 years

Remark: Not suitable for installation in recreational vehicles and similar premises.

TÜV Rheinland LGA Products GmbH
TÜVRheinland
Zertifizierungsstelle

® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.